



- NOTES:
1. PVC SLEEVE SHALL BE SCHEDULE 40 AND EXTEND 5' BEYOND EDGE OF PAVEMENT.
  2. ALL POLLY PIPE SHALL BE 200 PSI.

GENERAL NOTES:  
 (1) FOR ADDITIONAL INFORMATION, SEE CANYON LAKE WATER SERVICE COMPANY'S STANDARD SPECIFICATIONS.

BY	REVISION	DATE	CK	AP	OPS

**CLWSC**

CANYON LAKE  
 WATER SERVICE COMPANY  
 1399 Sattler Road  
 Canyon Lake, Texas 78133  
 (830) 964-3854

**STANDARD 1.5" DUAL SERVICE CONNECTION**

BY: MS	OPERATIONS / DATE
DATE: 04-26-17	ENGINEERING / DATE
CK:	DIRECTOR OF ENGINEERING / DATE
SCALE: NONE	

REF. NOS.
DWG. NO.
SHEET: 1 OF 1